

Clack® 

WS1.25TC

WATER SPECIALIST CONTROL VALVE



shown with optional bypass



Certified to NSF/ANSI 44, 61 and 372.

- More informative 4 digit LCD Display with Status Indicators
- Solid state microprocessor with easy access front panel settings
- Service flow rate of 34 gpm, backwash 32 gpm
- Backwash and brining ability to 21" diameter tanks
- Front panel display for time of day, days until next regeneration
- Days between regeneration feature: 1-99 days standard; 7-day optional
- Double backwash feature offers optimum regeneration, cleaning ability and efficiency
- 10 selectable pre-programmed regeneration cycles
- Coin Cell Lithium battery back-up with a 8 hour carry over
- Auto detection of 50/60 Hz line frequency, with automatic 12/24 hour time keeping formats
- 12-volt output AC Adapter provides safe and easy installation
- Patented one piece expanding seal spacer stack assembly U.S. Patent 6,402,944
- Patented linearly reciprocating piston operation U.S. Patent 6,444,127
- Post treated water regenerant refill
- Reliable and proven DC drive

Water Specialist 1.25" TC Control Specifications

Inlet/Outlet Fittings.....	¾" to 1.5" NPS
Cycles	up to 6
Valve Material	Noryl (1) or equivalent
Regeneration	downflow

FLOW RATES

Service @15 psi drop	34 gpm
Backwash @ 25 psi drop	32 gpm (2)
Cv Service	8.8
Cv Backwash	6.4

OPERATING PRESSURES

Minimum/Maximum	20 psi – 125 psi
-----------------------	------------------

OPERATING TEMPERATURES

Minimum/Maximum	40° – 110° F
-----------------------	--------------

DIMENSIONS & WEIGHT

Distributor Pilot.....	1.32" OD Pipe (1" NPS) or 32mm OD
Drain Line	¾" or 1" NPT
Brine Line	¾" or ½" OD Poly Tube
Mounting Base.....	2 ½" - 8 NPSM
Height From Top Of Tank.....	7 ¾"
Weight	4.5 lbs.

ELECTRICAL SPECIFICATIONS

AC Adapter

	U.S.	International
Supply Voltage	120V AC.....	230V AC
Supply Frequency	60 Hz.....	50 Hz
Output Voltage	12V AC.....	12V AC
Output Current	500 mA.....	500 mA

TANK APPLICATIONS

Water Softener	6" – 21" diameter
Water Filter (3).....	6" – 24" diameter

CYCLES OF OPERATION (Softener Downflow)

Cycle	Range of times minutes
1. Backwash 1 st (upflow).....	3 - 12
2. Regenerate Draw/Slow Rinse (downflow)	50 - 70
3. Backwash 2 nd (upflow)	3 - 12
4. Fast Rinse (downflow)	3 - 8
5. Regenerant Refill (in service with treated water).....	As Programmed
6. Service (downflow)	

Options: Backwash Filter, Bypass, Weather Cover

Compatible with the following typical concentration of regenerants or chemicals: Sodium chloride, potassium chloride, potassium permanganate, sodium bisulfite, chlorine and chloramines

1. Noryl is a trademark of Sabic Innovative Plastics IP B.V. Company
2. Aquired by use of external drain line flow control
3. Filter tank size calculated @ 10 gpm of backwash per square foot of bed area